



Certificate of Compliance

Certificate: 70045273 (033332_0_000)

Master Contract: 155387

Project: 70192328

Date Issued: 2018-08-21

Issued to: Rosemount Inc.
6021 Innovation Blvd.
Shakopee, Minnesota 55379-9795
USA

Attention: Erin Lemke

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Sze-Oi (Patrick) Ma
Sze-Oi (Patrick) Ma

PRODUCTS

CLASS - C225206 - PROCESS CONTROL EQUIPMENT

CLASS - C225286 - PROCESS CONTROL EQUIPMENT-Certified to US Standards

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

Pressure Module, Model 215, Rated 5-6Vdc, 3.0mA max; Rng 0: MWP 750 psig, Rng 1: MWP 3626 psig, Rng 2-4: MWP 6092 psig, Rng 5: MWP 4500 psig, Type 4X.

Notes:

1. The above model is permanently connected, Equipment Class III, Pollution Degree 4
2. Mode of operation: Continuous
3. Environmental Conditions: Normal: -40 to 85 C, 5000 m max, 0-100%RH



Certificate: 70045273

Project: 70192328

Master Contract: 155387

Date Issued: 2018-08-21

APPLICABLE REQUIREMENTS

CSA Standards:

CAN/CSA-C22.2 No. 61010-1-12

- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

CSA C22.2 No. 94.2-07

- Enclosures for Electrical Equipment, Environmental Considerations

UL Standards:

UL Std. No. 61010-1 (3rd Edition)

- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

UL Std. No. 50E (1st Editions)

- Enclosures for Electrical Equipment, Environmental Considerations



Supplement to Certificate of Compliance

Certificate: 70045273 (033332_0_000)

Master Contract: 155387

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70192328	2018-08-21	Update Report 70045273 to add 6092 psi (42 MPa) static pressure range
70045273	2015-11-16	Evaluation of pressure module Model 215 to standard 61010-1 3rd Ed. ((C/US) CSA C22.2 No. 61010-1-12, UL 61010-1 3rd Edition, CSA C22.2 No. 94.2-07, UL 50E 1st Ed.)